

UWM Physical Plant Services March 2007

UW-Milwaukee Emergency Generators 2007

Building	Room #	Mfg.	KW Rating	Fuel	Exhaust Gas CFM	Exhaust Gas Temperature of	Exhaust Location (Roof or Bldg. Side)	Exhaust Orientation (Up, down, or horiz.)	Exhaust Point Outlet Diameter	Exhaust Point Height above grade (estimated)	Oil-Acid spill kit	Comments:
Architecture	B33 E	Onan	100	Natural Gas	760	1025	Roof	Down	8 inches	66 feet		
Bolton	B 45	Kohler	30	Natural Gas	240	1100	North Side	Down into chase	10 inches	2 feet below grade		
Business (Lubar)	B 05	Adco	135	Natural Gas			Roof	Horizontal (45 degrees)	6 inches	2 feet below grade		
Chemistry	B49	Cummins-Onan	250	Diesel	nd	nd	between north south tower 4th floor	up	nd	4 stories		
Cunningham	B 97 A	Kohler	50	Natural Gas	685	1200	South Side	Up	3 inches	at grade		
Curtin	B 50 B	Kurz-Root	50	Natural Gas	685	1200	West Side	Horizontal	4 inches	< 1 foot		
EMS	1303	Kohler	50	Natural Gas	685	1200	North Side	Horizontal	4 inches	150 feet		
EMS Computer Lab	EB 47	Onan	80									
Enderis	B 33 B	Kohler	55	Natural Gas	240	1100	South Side	Down	4 inches	15 feet		
Engelmann	B 2	Kohler	55	Natural Gas	685	1200	Roof	Horizontal	6 inches	36 feet		
Garland	B 05B	Onan	37	Natural Gas	425	875	Roof	Horizontal	4 inches	42 feet		
Heating/Chilling Plant (maintained by HCP)	150	Cummins-Onan	440	Diesel	5850	985	South Side	Horizontal	10 inches	8 feet		
Holton	G 49A	Kohler	100	Diesel	750	1045	Roof	Up (45 degrees)	6 inches	58 feet		
Kenilworth Square Apartments	B02	Kohler	400	Diesel								
Kenilworth Square East	B02	Kohler	400	Diesel	nd	nd	nd	nd	nd	nd		
Klotsche	G214	Kohler	180	Natural Gas	nd	nd	nd	nd	nd	nd		
Lapham West (1991)	B38 A	Onan	900	Diesel	7575	865	Roof	Up	12 inches	70 feet		
Lapham West (2005)	bottom of drive, next to SB89B	Onan	350	Diesel	nd	nd	Roof	nd	nd	nd		
Library #1 (West)	WB 22	Kohler	100	Natural Gas	854	1300	West Side of West Wing	Horizontal	6 inches	10 feet		
Library #2 (East)	EB 57 B	Kurtz-Root	75	Natural Gas	500	900	West Side of East Wing	Up	6 inches	20 feet		
Mitchell	Outside 181 Lower Roof	Generac	60	Natural Gas	nd	nd	nd	nd	nd	25 feet		
Music	MB11 A	Adco	30	Natural Gas	320	1150	Ground level In mall	Horizontal	2 inches	15 feet		
Physics	505	Ready Power	27.5	Natural Gas	290	1100	Roof	Horizontal	3 inches	60 feet		
Sabin (verify if Sabin has a generator)	B 90	Onan	100	Natural Gas								

UWM Physical Plant Services March 2007

Building	Room #	Mfg.	KW Rating	Fuel	Exhaust Gas CFM	Exhaust Gas Temperature of	Exhaust Location (Roof or Bldg. Side)	Exhaust Orientation (Up, down, or horiz.)	Exhaust Point Outlet Diameter	Exhaust Point Height above grade (estimated)	Oil-Acid spill kit	Comments:
Sandburg Commons	By Police Dept. outside	Kohler	100	Natural Gas	854	1300	3rd Floor Roof	Down	6 inches	45 feet		
Sandburg East	EB 04	Cummins-Onan	375	Diesel	2435	870	North Side	Horizontal	9 inches	10 feet		
Sandburg Sprinkler System Auxiliary Power		Kohler	331	Diesel	785	2170	North of Commons at parking ramp	Horizontal	8 inches	12 feet		
Student Union (maintained by S.Union)	EB 30 A	Onan	100	Natural Gas	760	1025	North Side, facing East	Behind vertical louvers	6 inches	5 feet		
University Services Building (check whether USB has a generator)												
WATER Institute	321	Kohler	110	Natural Gas								
Zelazo	Above 127	Kohler	6	Natural Gas								
Zelazo	South side of building	Generac	22	Natural Gas								
Buildings without generators: Art, Art-Lecture, Art-Theatre, Chapman, Greene, Mellencamp, Merrill, Pearse,												